

**High Commission of India
Colombo**



CORRIGENDUM



Reference Tender No.Col/DC/228/01/2015 dated 06 May 2018 for Construction of a Surgical Unit at teaching Hospital, Batticaloa

Bidders may note the following changes in the Tender documents and instructed to submit this with the bid.

Invitation for Bids

8. Bids should be sent to the address below at registered post or by hand in duplicate to the Counsellor (Development Cooperation), High Commission of India, 36-38, Galle Road, Colombo-03 on or before 07 June 2018 at 1500 hrs. Late bids will be rejected. Bids will be opened soon after closing in the presence of the bidders' representatives who choose to attend.

Bidding Data

22.1 Deadline for submission of Bids

Deadline for submission of Bids. 1500 Hours, 07 June 2018

25.1 Bid opening time and Place

High Commissioner of India, No 36-38, Galle Road, Colombo-03, at 1530 Hrs on 07 June 2018

Bill of Quantities:

N r	Section	Reference in Bidding Document	Query	Clarification
1.	08- Bill of Quantities	BOQ Item 3E-1 to 3E-44	Provide detail drawing	Refer Drawing No. C802-44/2016-01/ARU/AR/DW/C-01 & C802-44/2016-01/ARU/AR/DW/C-02
2.	08- Bill of Quantities	BOQ Item 3E-54 to 3E-59 Stainless Steel hand rail	Provide detail drawing	Refer Drawing No. C802-44/2016-01/ARU/AR/SL/C-01
3.	08- Bill of Quantities	BOQ Item 3E-60 to 3E-62 G.I. Hand rail	Provide detail drawing	Refer Drawing No. C802-44/2016-01/ARU/AR/SL/C-02
4.	08- Bill of Quantities	BOQ Item 3F-1 to 3F-3 Aluminium partition	Provide detail drawing	Refer Drawing No. C802-44/2016-01/ARU/AR/DE/C-01

5.	08- Bill of Quantities	BOQ Item 3G-1 Tempered Glass Curtain Wall	Provide detail drawing	Refer Drawing No. C802-44/2016-01/ARU/AR/DE/C-02
6.	08- Bill of Quantities	BOQ Item 3J-01 Steel Roof trusses	Provide detail drawing	Refer Drawing No. C802-44/2016-01/SD/T/02
7.	08 - Bill of Quantities	BOQ Item 4A-1 "Construction of an approx. size of 600 x 600 mm water meter chamber as per the drawing and supply and fixing of water meter, 2 nos. of 32mm dia brass gate valves."	Provide details for water meter chamber	Refer Drawing No. C802/D-WSD/PL-01
8.	Section 08 - Bill of Quantities	BOQ Item 4E-1 "Allow for temporary deroute of existing disposal lines using sludge pump or any other method until the new connections complete."	Provide details including capacity of sludge to be removed and works to be carried out under this item	Two currently operating manhole should shift in about 2m closer to nurses quarters (flow rate 2 l/min, which can shut down during shift work) Man hole size (450mm X 450mm) Pipe size (110mm)
9.	Section 08 - Bill of Quantities	BOQ Item 4E-2 "Allow for connection new disposal lines to existing disposal line. Supply material and construct (approx. Size 300x200mm HxW) brick covering to cover 110mm or smaller dia. soil / waste pipe laid along wall edges up to duct."	Provide location of the existing line and the distance between new line & existing line	Existing line at the internal access road at entrance side of proposed building. Distance between new line & existing line is about 7m.
10.	Section 08 - Bill of Quantities	BOQ Item 4E-5 "Dewatering if required by portable self priming electric/ engine driven centrifugal pump with suction and delivery hoses 75mm minimum or equivalent.."	Provide water table	1m from existing ground level

1 1.	Section 08 - Bill of Quantities	BOQ Item 4E-7 “Allow sum for disinfection of clean water sump, pipe system and overhead storage tank as per specification and as directed by Engineer.”	Provide method to be carried out for disinfection and the capacity of overhead storage tank	Method statement is attached. capacity of overhead storage tank is 10,000 liters.
1 2.	Section 08 - Bill of Quantities	BOQ Item 6A, 6B, 6C, 6D	Provide drawing & Specifications	Details of the BOQ items are enough for pricing these items and no service drawings will be provided at the stage. Specification and Technical Schedule has been issued under Addendum.

Additional Documents

1. Specification for disinfection of water storage
2. Mechanical Specification
3. Technical Schedule for mechanical works

All other terms & conditions of the tender will remain unchanged. This Corrigendum will be part of the tender document.